



Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 13107202
Procuring Entity CARLOS HILADO MEMORIAL STATE UNIVERSITY
Title Procurement of Airconditioning Units with installation for the ITS and Internet Center of CHMSU Talisay Campus
Area of Delivery Negros Occidental

Solicitation Number:	RFQ 26-264	Status	Active
Trade Agreement:	Implementing Rules and Regulations	Associated Components	1
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 34)	Bid Supplements	0
Classification:	Goods	Document Request List	0
Category:	Airconditioning and Airconditioning Systems	Date Published	05/07/2026
Approved Budget for the Contract:	PHP 220,000.00	Last Updated / Time	05/07/2026 00:00 AM
Delivery Period:	30 Day/s	Closing Date / Time	13/07/2026 17:00 PM
Client Agency:			
Contact Person:	Rowena De la Vida Prado Administrative Assistant II Mabini Street Talisay City Negros Occidental Philippines 6115 63-34-7120005 Ext.142 63-939-9296624 bac.sec@chmsu.edu.ph		

Description

Republic of the Philippines
 CARLOS HILADO MEMORIAL STATE UNIVERSITY
 Talisay City, Negros Occidental
 Cell Phone #: 09205833046
 bac.sec@chmsu.edu.ph

REQUEST FOR QUOTATION

Date: JUNE 23, 2026
 Quotation No. 26-264

_____, PAGE 1 OF 2

Please quote your lowest price on the item/s listed below, stating the shortest time of delivery and submit your quotation duly signed by your representative not later than _____ in the return envelope attached herewith.

DR. MA RIZA T. MANALO
 BAC Chairman

NOTE:

1. ALL ENTRIES MAY BE TYPEWRITTEN OR LEGIBLY HANDWRITTEN
2. DELIVERY PERIOD WITHIN 30 CALENDAR DAYS
3. WARRANTY SHALL BE FOR A PERIOD OF SIX (6) MONTHS FOR SUPPLIES & MATERIALS, ONE (1) YEAR FOR EQUIPMENT, FROM DATE OF ACCEPTANCE BY THE PROCURING ENTITY
4. PRICE VALIDITY SHALL BE FOR A PERIOD OF _____ CALENDAR DAYS

5. G-EPS REGISTRATION CERTIFICATE SHALL BE ATTACHED UPON SUBMISSION OF THE QUOTATION
 6. BIDDERS SHALL SUBMIT ORIGINAL BROCHURES SHOWING CERTIFICATIONS OF THE PRODUCT BEING OFFERED

ITEM ITEM & DESCRIPTION QTY. UNIT UNIT PRICE TOTAL PRICE
 NO. (Pls. indicate brand offered)

ONE (1) LOT
 1 AIRCONDITIONING UNIT, with installation & testing, wall mounted 2 unit split type, 2.0HP, Inverter type, 1PH, 230V, 60Hz, (18,990Kj/h-20,777 Kj/h), EER: 10.05Kj/W-h - 13.8Kj/W-h, cooling seasonal performance factor: 5.0 and above, refrigerant: R32, remote with Auto swing function, digital display of temperature.
 Includes: labor, Materials and commissioning, installation of A/C unit (Indoor and Outdoor), Installation of refrigerant piping with 'white tape, rubber insulation, proper fixtures, and hanger support installation of circuit breaker with enclosure, installation of power supply, installation of condensate drain line with insulation, fabrication and installation of bracket and support assembly, designed with adequate clearance to allow safe and convenient access for future inspection, cleaning, and maintenance activities. testing and commissioning, restoration works
 Warranty: 1 year for parts and workmanship, and 5-10 years for compressor
 Note: Must be Authorized Service center
 The Supplier shall conduct and actual site visit for ocular inspection and shall coordinate with the TWG-RAC/GSO to verify the exact locations of the Indoor and Outdoor unit, and to determine the accurate estimation of piping and electrical wiring requirements.
 2 AIRCONDITIONING UNIT, With installation & testing, Window Type 3 unit 2.0HP, Inverter Type, 1PH, 230V, 60Hz (18,000Kj/h - 20,000Kj/h) EER: 10.05Kj/W-h - 13.8 kj/W-h, Cooling Seasonal Performance factor: 5.0 and above refrigerant: R32
 Warranty: 1 year for parts and workmanship, and 5-10 years compressor
 Note: Must be authorized service center

TOTAL
 *****Nothing Follows*****

TOTAL ABC = Php220,000.00
 PROCUREMENT OF AIRCONDITIONING UNIT FOR THE OFFICE USE OF ITS OFFICE AND INTERNET CENTER - TALISAY CAMPUS - A. TORRES
 PR# 26-509-0604 06-04-26
 INCOME 279-164-26-06 06-08-26

Line	Item No.	Product/Service Name	Description	Quantity	UOM	Budget (PHP)
1	1	ONE (1) LOT	AIR-CONDITIONING UNIT with Installation	1	Lot	220,000.00

Created by Rowena De la Vida Prado
Date Created 04/07/2026

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.



REQUEST FOR QUOTATION

Date: JUNE 23, 2026
 Quotation No. 26-264

PAGE 1 OF 2

Please quote your lowest price on the item/s listed below, stating the shortest time of delivery and submit your quotation duly signed by your representative not later than _____ in the return envelope attached herewith.


DR. MA RIZA T. MANALO
 BAC Chairman

NOTE:

1. ALL ENTRIES MAY BE TYPEWRITTEN OR LEGIBLY HANDWRITTEN
2. DELIVERY PERIOD WITHIN 30 CALENDAR DAYS
3. WARRANTY SHALL BE FOR A PERIOD OF SIX (6) MONTHS FOR SUPPLIES & MATERIALS, ONE (1) YEAR FOR EQUIPMENT, FROM DATE OF ACCEPTANCE BY THE PROCURING ENTITY
4. PRICE VALIDITY SHALL BE FOR A PERIOD OF _____ CALENDAR DAYS
5. G-EPS REGISTRATION CERTIFICATE SHALL BE ATTACHED UPON SUBMISSION OF THE QUOTATION
6. BIDDERS SHALL SUBMIT ORIGINAL BROCHURES SHOWING CERTIFICATIONS OF THE PRODUCT BEING OFFERED

ITEM NO.	ITEM & DESCRIPTION (Pls. indicate brand offered)	QTY.	UNIT	UNIT PRICE	TOTAL PRICE
	ONE (1) LOT				
1	AIRCONDITIONING UNIT , With installation & testing, wall mounted split type, 2.0HP, Inverter type, 1PH, 230V, 60Hz, (18,990Kj/h-20,777 Kj/h), EER: 10.05Kj/W-h - 13.8Kj/W-h, cooling seasonal performance factor: 5.0 and above, refrigerant: R32, remote with Auto swing function, digital display of temperature. Includes: labor, Materials and commisioning, installation of A/C unit (Indoor and Outdoor), Installation of refrigerant piping with 'white tape, rubber insulation, proper fixtures, and hanger support installation of circuit breaker with enclosure, installation of power supply, installation of condasate drain line with insulation, fabrication and installation of bracket and support assembly, designed with adequate clearance to allow safe and convenient access for future inspection, cleaning, and maintenance activities. testing and commisioning, restoration works Warranty: 1 year for parts and workmanship, and 5-10 years for compresor Note: Must be Authorized Service center The Supplier shall conduct and actual site visit for ocular inspection and shall coordinate with the TWG-RAC/GSO to verify the exact locations of the Indoor and Outdoor unit, and to determine the accurate estimation of piping and electrical wiring requirements.	2	unit		
2	AIRCONDITIONING UNIT , With installation & testing, Window Type 2.0HP, Iinverter Type, 1PH, 230V, 60Hz (18,000Kj/h - 20,000Kj/h) EER: 10.05Kj/W-h - 13.8 kj/W-h, Cooling Sesonal Performance factor: 5.0 and above refrigerant: R32 Warranty: 1 year for parts and workmanship, and 5-10 years compresor	3	unit		

Date _____ By _____
 Released (BAC) _____
 Returned (Supplier) _____

 Printed Name/Signature

 Tel. No./Cellphone No.

 Date _____

